

TEST CERTIFICATE

According to the Guideline for Hygienic Assessment of Organic Materials in Contact with Drinking Water (KTW Guideline; 7 March 2016)

Polypipe Italia srl
Localit  Pianmercato 5C-5D
Cicagna
16044 GENOVA
Italy

Test Certificate no.: 17-K-108
Validity: 02.08.2017 till 01.08.2022
Product: Fittings made from
Benvic IA 608/9735
Tradename: PVC fitting, 40 mm

The product PVC fitting, 40 mm has been tested in accordance with the Guideline on the hygienic assessment of organic materials in contact with drinking water of the German Environment Agency and has passed the test (according to test report 031700247-0005-1) for the following application and temperature range:

Product group	Cold water (23 �C)	Warm water (60 �C)	Hot water (85 �C)
Pipes and their linings DN < 80 mm (service and domestic pipes)	---	---	---
Pipe 80 mm � DN < 300 mm (distribution pipes)	---	---	---
Pipe DN � 300 mm (large distribution and mains)	---	---	---
Fittings, ancillaries DN < 80 mm	passed	---	---
Fittings, ancillaries 80 mm � DN < 300 mm	passed	---	---
Fittings, ancillaries DN � 300 mm	---	---	---
Components of fittings, ancillaries DN < 80 mm	---	---	---
Components of fittings, ancillaries 80 mm � DN < 300 mm	---	---	---
Components of fittings, ancillaries DN � 300 mm	---	---	---
Storage systems	---	---	---
Repair products for storage systems	---	---	---

Compliance to the requirements for enhancement of microbial growth has not been tested. If pipes, sealings, or fittings and ancillaries do not differ in their material composition and manufacturing process, testing of the smallest diameter of the product range is sufficient. This test certificate is valid from the date of issue and, given that the conditions and requirements remain unaltered, expires by 01.08.2022. Upon request the validity may be extended up to another 5-year term provided that the specifications of the KTW Guideline are met.

 

Dirkjan van den Berg / i.V. Kerstin Schubert
Kiwa

Kiwa GmbH
Am Weidenbruch 22
18196 Kessin (Rostock)

Tel. +49 (0)38208 637 0
Fax +49 (0)38208 637 28

www.kiwa.de

The test results and assessments refer exclusively to the examined test specimens and all applicable statutory regulations. The validity of this document expires in case of modifications in the composition of the material or the processing conditions. This present document may only be published and reproduced unabridged and unaltered.

